

## DECLARATION OF PERFORMANCE

According to Construction Products Regulation (EU) No 305/2011  
and Amended by Regulation (EU) No 574/2014

Document No. ...0786-CPR-21553...

1. Unique identification code of the product-type:

**Type 4400I Analog Multi Detector with Isolator**

2. Intended Use:

**Fire detection and fire alarm systems installed in and around buildings**

3. Manufacturer:

**Panasonic Corporation Tsu Factory**

**1668, Fujikata, Tsu-shi, Mie-ken, 514-8555, JAPAN**

4. Authorised representative:

**Niels Erdmann**

**Panasonic Testing Centre**

**Panasonic Marketing Europe GmbH**

**Winsbergring 15, 22525 Hamburg, Germany**

5. System/s of AVCP:

**System 1**

6a. Harmonised standard:

**EN54-5:2000+A1:2002**

**EN54-7:2000+A1:2002+A2:2006**

**EN54-17:2005 / AC:2007**

Notified body/ies:

**VdS Schadenverhütung GmbH      Accreditation No. 0786**

**Certificate of constancy of performance: 0786-CPR-21553**

6b. European Assessment Document: N/A

European Technical Assessment: N/A

Technical Assessment Body: N/A

Notified Body: N/A

7. Declared performance:

Essential characteristics	Performance	Harmonized technical specification		
		EN54-5:2000 + A1:2002	EN54-7:2000 + A1:2002 + A2:2006	EN 54-17:2005 / AC:2007
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	Passed	4.2, 4.3, 5.2 to 5.6, 5.8, 6.1 <sup>a</sup> , 6.2 <sup>b</sup>	4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18	5.2 <sup>c</sup>
Operational reliability	Passed	4.4 to 4.11	4.2 to 4.7, 4.9 to 4.11	4
Tolerance to supply voltage	Passed	5.7	5.5	5.3
Durability of operational reliability and response delay; temperature resistance	Passed	5.9, 5.10	5.8, 5.9	5.4, 5.5
Durability of operational reliability; vibration resistance	Passed	5.14 to 5.17	5.13 to 5.16	5.9 to 5.12
Durability of operational reliability; humidity resistance	Passed	5.11, 5.12	5.10, 5.11	5.6, 5.7
Durability of operational reliability; corrosion resistance	Passed	5.13	5.12	5.8
Durability of operational reliability; electrical stability	Passed	5.18	5.17	5.13


<sup>a</sup> Suffix S detector only      <sup>b</sup> Suffix R detector only

<sup>c</sup> This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices.

8. Appropriate Technical Documentation and/or Specific Technical Documentation: N/A


The performance of the product identified is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above:

Signed for and on behalf of the manufacturer by:

(Signature):   
 (Printed name): Hisashi Taniguchi  
 (Title): Director

Place and date of issue  
 Japan, 22, Nov, 2019

Authorised Representative in EU:

(Signature):   
 (Printed Name): Wolfram Kühl  
 (Date): 27. Nov. 2019

Panasonic Testing Centre  
 Panasonic Marketing Europe GmbH  
 Winsbergring 15, 22525 Hamburg, Germany